

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000561-01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Building hardware - Controlled door closing devices - Requirements and test methods (refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: Ryobi Limited
5-2-8, Toshima Kitaku, Tokyo, 114-8518, Japan

and produced in the manufacturing plant(s): SG-15476

Intended use: On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 1154:1996/A1:2002/AC:2006

Under System 1 for the performances set out in this certificate are applied and that the performance of the construction product fulfils all the prescribed requirements for these performances.

This certificate replaces **0359-CPR-000561-01** first issued on **2017-08-16** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.



The issued document and statement(s) herein makes reference only to a presumption of conformity in accordance with the CPR Regulations EU 305/2011 (as amended). However, it is the manufacturer's or their authorised representative's sole responsibility to affix the CE logo and, by doing so, confirms full compliance and conformity to all other European mandatory directives and regulations that may also apply.

Signature:

92130



Date: 2019-10-25

Issue: 01

Name:

Dipl.-Ing. Roland Heine

Position: Certification Manager

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000561-01

APPENDIX TO: Certificate of Constancy of Performance

Brand: --
Model Ref: D-1200

Table A1. Mechanical test reports & Product classification for Door Closer from Ryobi Limited

Test Report	Model tested	Product Classification					
170712116GZU-001	D-1200	4	8	4	1 ^a	1	3
				3			
Evaluated function: Standard arm installation, Selectable Power Size 3 to 4 changed by reversing arm shoe. With speed control and latch control, Backcheck							

Table A2. Fire test report(s) for Door Closer from Ryobi Limited^b

Test Report	Model tested	Test Method	Fire resistance (minutes)	
			E - Integrity	I - Insulation
170717002SHF-BP-1	D-1200	EN 1634-1:2014	123	25

Notes.

- Digit 4 grade "1" was based on the test result from fire resistance test (refer to Table A2).
- The door closer shall be installed in accordance with the installation instructions for the product(s).

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-000561-01

APPENDIX TO: Certificate of Constancy of Performance

Table A3. EN 1154 Annex ZA Related Information for Door Closer from Ryobi Limited

Product:	Controlled door closing devices D-1200	
Intended use:	On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors) -Standard installation	
Requirement/ characteristic	Standard clause	Result Summary
Self-closing	General (5.2.1)	Grade 4 (closing doors from 180° open)
	Closing moment (5.2.3)	Power size 3 to 4
	Opening moment (5.2.4)	Power size 3 to 4
	Efficiency (5.2.5)	Power size 3: More than 55% Power size 4: More than 60%
	Closing time (5.2.6)	Pass
	Angles of operation (5.2.7)	Grade 4, 180°
	Overload performance (5.2.8)	Pass
	Temperature dependence (5.2.9)	Pass (-15°C to +40°C)
	Fluid leakage (5.2.10)	Pass
	Damage (5.2.11)	Pass
	Latch control (5.2.12)	Pass
	Backcheck (5.2.13)	Pass
	Delayed closing (5.2.14)	Pass
	Adjustable closing force (5.2.15)	Without inbuilt adjustable power size function.
Zero position (5.2.16)	NPD	
Durability of self-closing	Durability (5.2.2)	500,000 test cycles
	Corrosion resistance (5.2.2 5.2.17.1, 5.2.17.2)	Grade 3, Neutral Salt Spray (NSS) for 96 hours
Dangerous substances	See Clause ZA.3	No dangerous substances declared for this product/ intended use

END OF DOCUMENT

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.